

## Straight Edge Construction, Inc.

207 Main Street  
FREEPORT, MAINE 04032  
**(207) 865-3852**

November 1, 2020

### Water Commissioner Report

The wells have been tested twice this year. First test, the Community House's and Ewing's wells tested present for coliform. The second test, the Brewer Cottage's and Ewing's wells tested present for coliform. A boiled order was posted on those wells. With the drought this year, no wells have gone dry, that I am aware of.

Thanks you,  
Crawford Taisey